

# **FIRE SAFETY PRINCIPLES FOR RESIDENTIAL ACCOMMODATION**

Department of Place  
Economy and Development  
Housing Standards Team

## **Foreword**

This document has been produced by the City of Bradford Metropolitan District Council, in consultation with the West Yorkshire Fire and Rescue Service. It is based on the national guidance document produced by LACORS, *Housing – Fire Safety, Guidance on fire safety provisions for certain types of existing housing* LACORS - Fire safety published in July 2008 and aims to provide guidance for the design of fire safety schemes for residential accommodation in all tenure groups, including owner-occupied, social housing providers as well as those in the private rented sector. This guidance also takes into consideration the British Guidance BS 5839: 2020 + A1:2020 which outlines the code of practice for the design, installation, commissioning and maintenance of fire detection and fire alarm systems in domestic properties and replaces previous Fire Safety Principles issued by Bradford City MDC.

This guide offers practical advice on undertaking fire risk assessments and contains case studies of fire safety solutions in a range of property types. It aims to provide recommendations and guidance when assessing the adequacy of fire precautions and does not set prescriptive standards. Where there is doubt on the suitability of a fire safety scheme, then further advice can be sought from Bradford Council, Housing Standards or HMO Team or alternatively, West Yorkshire Fire & Rescue Authority (“WYFRA”).

**Housing Standards Team**, Bradford City MDC, for queries relating to single household properties 01274 434520

**HMO Team**, for queries relating to non-licensable HMOs, licensed and licensable HMOs 01274 434520

**Bradford District Fire Prevention**, West Yorkshire Fire and Rescue Service 01274 385432

**Planning, Transportation & Highways** for all queries relating to planning and building control matters 01274 432111

It is important to note that some fire safety works may be classed as building works for the purpose of building regulations and therefore approval maybe required from the local authority’s Building Control Services. Similarly new-build residential accommodation or conversions where there is a change of use of an existing building to a house in multiple occupation or self contained flats may also require planning permission.

*This document may be periodically revised so please check that you have the current edition. This can be done by either telephoning the Housing standards Team (details above) or by visiting the councils website: [www.bradford.gov.uk](http://www.bradford.gov.uk)*

## **Introduction**

This fire safety guide applies to all buildings constructed or converted for use as domestic dwellings and includes single and shared households, bedsit HMOs, purpose built flats and buildings converted into self-contained flats to a standard that does not comply with the Building Regulations 1991, sheltered accommodation where no personal care is provided and small hostels where the HM Government Sleeping Accommodation Guide\* does not apply. Where self contained flats did meet the 1991 Building Regulations standards but they are now in a poor condition due to a lack of maintenance, damage or alteration, or where they are occupied in a manner other than intended (i.e. in multiple occupation) then appropriate additional measures from this guide can be applied.

The guide does not apply to a range of other residential uses, including guest houses and hotels used by visitors, large hostels, refuges, residential training and conference centres and health and beauty spa centres, student halls of residence, boarding schools, residential care homes and workplaces where employees sleep on the premises as a business requirement e.g. a hotel. For these premises the Regulatory Reform (Fire Safety) Order 2005 (“FSO”) applies and guidance is contained in the HM Government Sleeping Accommodation Guide\*.

The FSO introduced duties on the *responsible person*, (ie. the person in control of premises) in relation to fire safety in the common parts of HMOs, flats, maisonettes, bedsits and sheltered accommodation where no personal care is provided. The duty is to carry out a *fire risk assessment* and to take specific action to minimise the risk of fire in common parts. Whilst the assessment is of common parts only, in practice it will take into account the whole of the premises including all units of accommodation. It is important to note that the FSO does *not* apply to HMOs that are occupied as shared houses. The FSO is enforced by the fire and rescue authorities. There is a small section in this guide that covers the key aspects of undertaking a fire risk assessment in smaller residential premises. Specialist advice should be sought for larger, complex premises or premises with mixed use.

In addition to the FSO, fire safety in residential accommodation is also covered by the Housing Act 2004, by way of the housing, health and safety rating system (“HHSRS”), the licensing provisions for HMOs and the management regulations for HMOs. This legislation is enforced by local authorities.

As there is a dual enforcement role for fire safety, the general protocol in Bradford is that the council will lead on single households, shared houses (Category B HMOs), bedsits (Category A HMOs) and self-contained flats, whilst WYFRA will lead on mixed use premises, sheltered housing, large hostels, hotels and bed and breakfast accommodation and all multiply occupied property managed and owned by the local authority. In dual enforcement situations Bradford City MDC may take action in consultation with WYFRA.

---

\* HM Government Fire Risk Assessment: Sleeping Accommodation Guide published by Communities and Local Government in May 2006

## **Contents**

### **1.0 THE PRINCIPLES OF RISK ASSESSMENT FOR FIRE SAFETY**

- 1.1 Identifying Fire Hazards in Premises
- 1.2 Factors that Increase the Risk of Harm from Fire
- 1.3 Fire Safety Measures
- 1.4 The Basic Principles of Undertaking a Fire Risk Assessment

### **2.0 DESIGN PRINCIPLES FOR FIRE SAFETY SCHEMES**

#### **2.1 Converted Buildings Comprising of Self-Contained Flats**

- 2.1.1 Three or Four Storey Buildings
- 2.1.2 Two Storey Buildings

#### **2.2 Category A HMOs (HMOs Occupied as Bedsits and Non-Self Contained Flats)**

- 2.2.1 Three or Four Storey Buildings
- 2.2.2 Two Storey Buildings

#### **2.3 Category B HMOs (Shared Houses)**

- 2.3.1 Large Shared (Higher Risk) HMOs - Three to Four Storeys
- 2.3.2 Medium Sized (Lower Risk) Shared HMOs - Three to Four Storeys.
- 2.3.3 Small Shared HMO - Up to two Storey

#### **2.4 Single Household Properties**

- 2.4.1 Three to Four Storey Buildings
- 2.4.2 Up to Two Storey Buildings

#### **2.5 Back-to-Back Houses (Singly and Multiply Occupied)**

- 2.5.1 Two to Three Storey Back-to-Back – Shared House
- 2.5.2 Two to Three Storey back to Back – Single Household

#### **2.6 Basements and Cellars**

- 2.6.1 Habitable Basements
- 2.6.2 Unoccupied Basement/Cellars

#### **2.7 Mixed use Premises – Commercial and Domestic**

### **3.0 GLOSSARY**

## **1.0 The Principles of Risk Assessment for Fire Safety**

A fire risk assessment is a methodical inspection of premises, examining the activities undertaken there, the likelihood of a fire starting and the risk of harm occurring to occupiers and people around the premises. The aim of the assessment is to identify fire hazards, reduce the risks of hazards causing harm to as low as reasonably practicable, and to decide what physical fire precautions and management arrangements are necessary to ensure the safety of people within the building if a fire does occur.

### **1.1 Identifying Fire Hazards in Premises**

A hazard is anything that has the potential to cause harm. In terms of a fire safety risk assessment the following hazards should be considered -

**The vulnerability of occupiers** – People at risk must be considered. This may include the elderly and the young; people with personal challenges such as drug abuse or alcohol dependency; people with disabilities that would affect them using the means of escape without assistance (i.e. impaired mobility, hearing or vision) and people with difficulty understanding English.

**Sources of ignition** – Potential sources of heat that could get hot enough to ignite surrounding materials should be considered. These may include:

- Cookers, toasters and other kitchen equipment (especially when shared);
- Radiant and portable space heaters;
- Smokers materials such as cigarettes, matches and lighters (if people smoke within the premises);
- Faulty or misused electrical appliances;
- Electrical wiring in poor condition;
- The gas installation;
- An inadequate number of electrical power points causing overloading, and
- Naked flames such as candles and night lights.

**Sources of fuel** - Anything that burns is fuel for a fire. Therefore a risk assessment should identify things that burn reasonably easily and that are in large enough quantity to provide fuel for a fire or cause it to spread to other fuel sources. Sources of fuel include:

- Non-fire retardant fabrics and furnishings;
- Textiles, bedding, clothing, curtains and laundry;
- Accumulations of unwanted mail, paper, cardboard, books, etc;
- Flammable liquid-based products such as varnish, paint, thinners, etc;
- Plastics and rubber such as video tapes, and
- Wall, floor and ceiling coverings and surface finishes.

## 1.2 Factors that Increase the Risk of Harm from Fire

The main building characteristics that increase the risk of death or injury from a fire include the following:

- The number of occupiers;
- The number of storeys;
- The travel distance to evacuate the building;
- The complexity of the escape route;
- The presence of final exit doors requiring the use of a key for opening;
- The location of the kitchen;
- Flammable materials within the escape route, including wall coverings, furniture and fittings;
- The size of rooms;
- The presence of key operated security grilles fixed to escape windows and external doors, and
- Rooms where the means of escape is through another high fire risk room, i.e. through a kitchen and/or living room.

## 1.3 Fire Safety Measures

The following fire safety measures will reduce the risk of death or injury from fire:

- The provision of a 30 or 60 minute fire protected route of escape;
- Fire separation between units of accommodation, including walls & ceilings;
- The provision of fire doors with intumescent strips (and cold smoke seals as necessary) and self closing devices;
- Automatic and manual fire detection systems;
- Emergency lighting;
- Whole stair lighting;
- Escape windows;
- Sprinkler and mist systems, and
- Fire extinguishers and fire blankets.

## 1.4 The Basic Principles of Undertaking a Fire Risk Assessment

When carrying out a risk assessment the responsible person should consider the hazards and factors outlined in paragraphs 1.1-1.3 to enable them to determine the following:

- The likelihood that a fire may cause death or injury;
- The building characteristics that could increase the risk of harm, and
- What fire safety measures are needed to reduce the fire risk to a reasonably acceptable level or to minimise the likelihood of harm should a fire start. This could include for example, raising the occupiers awareness of fire safety; removing potential sources of ignition and providing fire safety measures as outlined in paragraph 1.3 above.

## **2.0 Design Principles for Fire Safety Schemes**

The fire safety schemes detailed in this guide are based on properties which present a *normal risk*, i.e. there are no factors that increase the level of risk in the property and the occupiers are not from high risk groups. Where such factors exist, or if a property deviates from the types listed below, then the risk can be deemed higher and accordingly a higher level of fire protection may be appropriate. Please note the LACORS guidance also proposes the possibility of some properties being classified as to be of lower risk. A definition of the applicable criteria can be found in the glossary to this document.

### **2.1 Converted Buildings Comprising of Self-Contained Flats**

These are houses or buildings that have been converted into self-contained flats and where the conversion did not and does not meet the building standards under the Building Regulations 1991. Buildings that were converted in accordance with these regulations should not require any further fire safety measures unless they are occupied in a manner other than intended under the original conversion scheme e.g. occupation of a flat as an HMO, or where an additional risk has been introduced post-conversion. Self-contained flats comprise single or multi-room lets with exclusive amenities and behind the flat's exclusive entrance door.

#### **2.1.1 Three or Four Storey Buildings Converted into Self-Contained Flats**

Where one or more floor level exceeds 4.5 metres above the ground level:

- A 30 minute protected route of escape in the building with FD30S doors (with self closing devices fitted) to entrances of flats where they open onto the route of escape.
- There is generally no requirement for a 30 minute protected route within the flats but sound, well constructed and close fitting conventional doors are required. The route of escape must not pass through a risk room. See glossary - Inner rooms. Where there are poor construction standards, long travel distances or high risk factors, a 30 minute protected route will be required within the flat and/or an increased level of fire detection within the flat.
- Fire separation: 30 minutes fire resistance between flats throughout is the ideal, but on risk assessment there may be no requirement for additional fire-resisting separation between units providing walls and floors are of sound, traditional construction and additional compensatory detection is fitted.
- A mixed grade automatic fire detection (AFD) is required comprising an LD2 Grade A AFD to the common areas of the building and an interlinked heat detector in each flat located in the room/lobby opening onto the route of escape *plus*:
  - for a flat occupied by a single household, a non-interlinked LD3 Grade D1 smoke alarm in each individual flat, located in the room/lobby opening onto the escape route. This is to protect the sleeping occupants of the flat, or
  - for a one storey flat in multiple occupation, an interlinked LD3 Grade D1 smoke alarm in each flat, located in the internal hall and a heat detector in the communal kitchen, or

- for a two storey flat in multiple occupation, an interlinked LD3 Grade D1 smoke alarm each flat, located in the escape route at each level, communal lounge and a heat detector in the communal kitchen.

Where a risk assessment identifies a higher than normal risk, rooms within flats requiring automatic fire detection may include living rooms, kitchens and bedrooms, in which a Grade D1 system should be used to prevent whole house false alarms.

In addition to the required AFD the design of the building shall also incorporate the following:

- A dedicated lighting circuit should be installed so that the use of any one switch/control anywhere along the route will illuminate the entire escape route;
- A manual call point
- Final exit and signage along the escape route if the escape is complex;
- Fire blankets are recommended in the kitchens of flats occupied by single households and are required in the kitchens of multiply occupied flats;
- A multi-purpose fire extinguisher is recommended at each floor in the common parts of the building containing the flats;
- Emergency lighting is only required in the escape route for the building containing the flats and in flats that are in multiple occupation, where the escape route is long and complex or where there is no effective borrowed light, and
- See section 2.6 regarding the requirement for FD30s at the head of the basement and other requirements

### 2.1.2 Two Storey Buildings Converted into Self-Contained Flats

Where no floor level exceeds 4.5 metres above the ground level:

- A 30 minute protected route of escape with FD30S doors (with self closing devices fitted) to entrances of flats where they open onto the route of escape.
- There is no requirement for fire doors within flats but sound, well constructed and close fitting conventional doors are required. For flats occupied by single households, a lower standard of protection in the protected route may be acceptable where there are suitable escape windows from bedrooms and living rooms (see the Glossary for escape window requirements);
- The route of escape must not pass through a risk room See Glossary - Inner rooms. Where there are poor construction standards, long travel distances or high risk factors, a 30 minute protected route will be required within the flat and/or an LD2 AFD within the flat.
- A mixed grade AFD comprising an LD2 Grade D1 AFD to the common areas of the building and an interlinked heat detector in each flat, in the room/lobby opening onto the route of escape, *plus*:
  - for a flat occupied by a single household, a non-interlinked LD3 Grade D1 smoke alarm in each individual flat, located in the room/lobby opening onto the escape route. This is to protect the sleeping occupants of the flat, or
  - for a one storey flat in multiple occupation, an interlinked LD3 Grade D1 smoke alarm in each flat, located in the internal hallway and a heat alarm in the communal kitchen, or



- for a two storey flat in multiple occupation, an interlinked LD3 Grade D1 AFD in each flat, located in the escape route at each level with an interlinked smoke alarm in the communal lounge and an interlinked heat alarm in the communal kitchen.

Where a risk assessment identifies a higher than normal risk, rooms within flats requiring automatic fire detection may include living rooms, kitchens and bedrooms, in which a Grade D1 system should be used to prevent false alarms.

In addition to the required AFD the design of the building shall also incorporate the following:

- A dedicated lighting circuit should be installed so that the use of any one switch/control anywhere along the route will illuminate the entire escape route;
- Fire blankets are recommended in the kitchens of flats occupied by single households and are required in the kitchens of multiply occupied flats;
- A multi-purpose fire extinguisher is recommended at each floor in the common parts of the building containing the flats;
- Emergency lighting is only required in the escape route for the building containing the flats and in flats that are in multiple occupation, where the escape route is long and complex or where there is no effective borrowed light;
- See section 2.6 regarding the requirement for FD30s at the head of the basement and other requirements

## **2.2 Category A HMOs (HMOs Occupied as Bedsits and Non Self-Contained Flats)**

These are HMOs that contain a number of individual lettings. Each letting has the exclusive use of certain rooms (this maybe specified in a tenancy agreement) and each letting door usually has a lock on it. Occupiers may share some or all of the basic amenities (washing, toilet and kitchen facilities) or they may have their own amenity within or outside their unit of accommodation, for example:

- A single room bedsit with no facilities within the room, the occupier shares the communal bathroom and kitchen.
- A single room bedsit with en-suite bathing facilities; the occupier shares the communal kitchen.
- Flatlets/bedsits with incorporated kitchen facilities the occupiers share the communal bathroom facilities. Some occupants may share a communal kitchen if not all lets have kitchenette within their room.
- In none self-contained flats (single or multi-room lettings) tenants have amenities for their own exclusive use but they are not all located behind one door

Category A HMOs tend to not have a communal living room and are let to individuals or couples. The occupiers of the HMO live independently with little or no communal living.

### **2.2.1 Category A HMO - Three to Four Storey Buildings**

Where one or more floor level exceeds 4.5 metres above the ground level:

- A 30 minute protected route of escape with FD30S doors with self closing

devices to all risk rooms that open onto the route of escape. Travel distance must not be excessive

- Fire separation between units shall meet 30 minutes fire resistance. Where the fire risk assessment identifies specific higher risks then a higher standard of fire resistance may be required (usually 60 minutes).
- AFD is required

#### **Bedsits with cooking facilities located within the bedsit –**

- A mixed grade LD2 Grade A AFD system with interlinked smoke detectors on the escape route, any basement/cellar area and heat detectors in all kitchenettes. These detectors must be linked to the control panel (located on the inside wall to the exit door to give information on the location of fire or any system fault)
- In addition; this system must be complemented by an independent Grade D1 system (non-interlinked single point smoke detection with integral battery back up) within the individual bedsits.

#### **Bedsits where cooking facilities are sited within shared kitchens -**

- LD2 Grade A AFD with interlinked smoke detectors on the escape route, any basement/cellar area and in all individual bedsits, plus heat detectors in each communal kitchen. These detectors must be linked to a control (located on the inside wall to the exit door to give information on the location of fire or any system fault)

In addition to the required AFD the design of the HMO shall also incorporate the following:

- A dedicated lighting circuit should be installed so that the use of any one switch/control anywhere along the route will illuminate the entire escape route;
- Final exit and signage along the escape route if the escape is complex;
- A fire blanket is required in each bedsit with cooking facilities and in any shared kitchen;
- Emergency lighting is only required in the escape route where the route is long and complex **or** where there is no effective borrowed light;
- See section 2.6 regarding the requirement for FD30s at the head of the basement and other requirements
- The electrical supply to any fire detection and alarm system must be connected to the landlords' supply that must not operate via a card or coin operated meter or similar device.
- Manual call points located adjacent to each final exit door and on each floor level. The need for additional call points should be risk assessed.
- Locks on any bedrooms and final exit doors must be capable of being opened from the inside without the use of a key.
- The escape route must be clear of obstructions and combustible materials.

### **2.2.2 Category A HMO - Two Storey Buildings**

Where no floor level exceeds 4.5 metres above the ground level:

- A 30 minute protected route of escape with FD30S doors with self closing devices to all risk rooms opening onto the route of escape. Travel distance must not be excessive. However, in a normal risk 2 storey HMO the provision

of suitable escape windows from all bedsit rooms may be acceptable in lieu of a fully protected route (see the glossary for escape window requirements);

- Fire separation between units shall meet 30 minutes fire resistance.
- AFD is required

#### **Bedsits with cooking facilities located within the bedsit –**

- A mixed grade LD2 Grade D1 AFD system with interlinked smoke detectors on the escape route, any basement/cellar area and heat detectors in all bedsits. In addition; this system must be complemented by an independent Grade D1 system (non-interlinked single point smoke detection with integral battery back up) within the individual bedsits.

#### **Bedsits where cooking facilities are sited within shared kitchens–**

- A LD2 Grade D1 AFD with interlinked smoke detectors on the escape route, any basement/cellar area and in all individual bedsits plus heat detection in each communal kitchen.

In addition to the required AFD the design of the HMO shall also incorporate the following:

- A dedicated lighting circuit should be installed so that the use of any one switch/control anywhere along the route will illuminate the entire escape route;
- Final exit and signage along the escape route if the escape is complex;
- A fire blanket is required in each bedsit with cooking facilities and in any shared kitchen;
- Emergency lighting is only required in the escape route where the route is long and complex **or** where there is no effective borrowed light;
- See section 2.6 regarding the requirement for FD30s at the head of the basement and other requirements
- The electrical supply to any fire detection and alarm system must be connected to the landlords' supply that must not operate via a card or coin operated meter or similar device.
- Manual call points located adjacent to each final exit door and on each floor level. The need for additional call points should be risk assessed.
- Locks on any bedrooms and final exit doors must be capable of being opened from the inside without the use of a key.
- The escape route must be clear of obstructions and combustible materials.

## **2.3 Category B HMOs (Shared Houses)**

These are houses occupied on a shared basis by 3 or more people who belong to more than one household. These HMO's are rented to a defined social group, commonly students, young professional adults, work colleagues and friends. The occupiers each enjoy exclusive use of a bedroom but would share other facilities such as communal lounge, kitchen/dining facilities, bathrooms and WC facilities.

The occupiers of a shared HMO tend to have the characteristics of a single household by living as a cohesive group and often share a living room. The HMO is usually rented out by 1 group and typically but not always on a single joint contract.

Shared houses have a different standard of AFD to that of bedsit type accommodation. If the mode of occupation within the HMO changes from a shared house to bedsit, the requirements as set out in section 2.2 will apply. This may result in additional fire safety measures.

### **2.3.1 Large Shared (Higher Risk) HMO – Three\*\* to Four Storey Building.**

- A 30 minute protected route of escape with FD30 doors (without smoke seals) with self closing devices to all risk rooms opening onto the route of escape. Travel distance must not be excessive;
- Where exit from the property is possible in more than one direction at ground floor level via risk rooms (ie either the front or rear rooms) then FD30S doors between these ground floor rooms and the staircase will be required. Vision panels must be provided in these doors to allow tenants to identify the source of the fire and the appropriate route of escape;
- Fire separation between units shall meet 30 minutes fire resistance.
- LD2 Grade D1; including interlinked mains wired smoke detection in the escape route at each floor level, lounge, separate dining room and cellar with heat detection in the kitchen
- The electrical supply to any fire detection and alarm system must be connected to the landlord's supply that must NOT operate via a card or coin operated meter or similar device
- A dedicated lighting circuit should be installed so that the use of any one switch/control anywhere along the route will illuminate the entire escape route.
- Signage along the escape route if it is complex;
- A fire blanket in each shared kitchen is required;
- Emergency lighting is only required in the escape route where the escape route is long and complex **or** where there is no effective borrowed light;
- The escape route must be clear of obstructions and combustible materials.
- See section 2.6 regarding the requirement for FD30s at the head of the basement and other requirements

#### **\*\* In three-storey properties only**

The ideal situation is for the escape route to be enclosed in 30-minutes fire resisting construction and FD30 fire doors. However, in existing three-storey shared houses of low risk it may be possible to accept existing walls and partitions if 20-minutes fire resistance can be achieved. This is likely to be met if

walls and partitions are of sound, conventional construction. Sound lath and plaster construction should meet this requirement. Doors onto the escape route may be acceptable if they are of sound, solid construction, are close fitting and self-closing

### **2.3.2 Small Shared HMO - Up To Two Storey Buildings.**

- There is no requirement for a full 30 minute protected route of escape, but the escape route should have traditional construction and not pass through risk rooms. There is no requirement for fire doors but sound, well constructed and close fitting conventional doors are required. Alternatively suitable escape windows can be provided from bedrooms and living rooms.  
*Note: that where construction standards are poor in the route of escape, travel distances are long or other high risk factors are present a 30 minute protected route of escape may be required;*
- LD2 Grade D1; including interlinked mains wired smoke detection located in the escape route at all floor levels, lounge, separate dining room and cellar with heat detection in the kitchen
- A fire blanket in each shared kitchen is required; and
- See section 2.6 regarding the requirement for FD30s at the head of the basement and other requirements

## **2.4 Single Household Occupancy Properties**

These are houses, flats and maisonettes occupied by persons living as a single household (please see the Glossary for the definition of household).

### **2.4.1 Three to Four Storey Buildings**

- There is no requirement for a full 30 minute protected route of escape but the escape route should have sound conventional construction not passing through risk rooms and travel distance should not be excessive. There is no requirement for fire doors but sound, well constructed and close fitting conventional doors are required.  
*Note: where construction standards are poor in the route of escape, travel distances are long or other high risk factors are present a 30 minute protected route of escape may be required;*
- LD2 Grade D1 AFD; including interlinked mains wired smoke detection located in the escape route at all floor levels, lounge, separate dining room and cellar with heat detection in the kitchen
- A fire blanket in each kitchen is recommended
- See section 2.6 regarding the requirement for FD30s at the head of the basement and other requirements
- Where exit from the property is possible in more than one direction at ground floor level via risk rooms (ie either the front or rear rooms) then FD30s doors between these ground floor rooms and the staircase will be required.

### **2.4.2 Up to Two Storey Buildings**

- There is no requirement for a full 30 minute protected route of escape but the

escape route should have sound conventional construction, not passing through risk rooms and travel distance should not be excessive. There is no requirement for fire doors but sound well constructed and close fitting conventional doors are required. Alternatively suitable escape windows can be provided from bedrooms and living rooms.

*Note: where construction standards are poor in the route of escape, travel distances are long or other high risk factors are present a 30 minute route of escape may be required;*

- LD2 Grade D1 AFD; including interlinked mains wired smoke detection located in the escape route at all floor levels lounge, separate dining room and cellar with heat detection in the kitchen
- A fire blanket in each kitchen is recommended
- See section 2.6 regarding the requirement for FD30s at the head of the basement and other requirements
- Where exit from the property is possible in more than one direction at ground floor level via risk rooms (ie either the front or rear rooms) then FD30s doors between these ground floor rooms and the staircase will be required.

## **2.5 Back-To-Back Houses (Single and Multiply Occupied Households)**

These are houses that back directly onto another at the party wall and have other properties at either side. This results in there being only one route of escape out of the property. In a high number of cases this route passes through a risk room, thus creating a situation where all bedrooms in the property become inner rooms. See Glossary - Inner rooms.

In larger double fronted back-to-back properties, the route of escape can come down the middle of the property to the final exit door. Where this situation arises the fire design principles for this type of back-to-back can follow the schemes detailed for the appropriate property type, for example a 2 or 3 storey building, and the mode of occupation (i.e. single household, flats, Category A HMO or Category B HMO).

**Solutions for back-to-back houses will inevitably rely heavily on the following main principles:**

- The provision of a suitable escape window\*\* at first floor level accessible to all occupiers of the upper floors.

*Note: Where the escape window is from a habitable room within a shared house, the door to that room must not be fitted with locks and any tenancy agreement should ideally prohibit the fitting of locks*

- A suitable automatic fire detection and warning system.
- An appropriate degree of fire separation between the ground floor and the upper floors. Full 30-minute separation will usually be appropriate with a FD30S fire door at the foot of the stairs leading from the ground floor to the first floor; and where a basement or cellar exists then the guidance below should be applied, with higher standards of separation as appropriate in the higher risk back-to-back properties.

\*\* Where the conditions for escape windows cannot be met other solutions will need to be adopted and may include:

- The construction of a 30-minute protected escape route inside the house

- 60-minute separation between the ground and first floors
- The installation of a water suppression system
- The setting of conditions relating to facilities for calling the fire and rescue service in an emergency

### 2.5.1 Two to Three Storey Back-to-Back (Shared House up to 4 Occupiers)

- A 30 minute protected route of escape at the first and second floor levels, with FD30 doors to risk rooms on those floors;
- In all cases the door separating the ground to first floor should at least be FD30S. However in circumstances where the staircase from first to ground floor extends into the ground floor living room, then it may not be possible to fit a FD30S. In such cases it will be permissible to fit a fire door blank (a door which can be cut to any size) with intumescent strip and cold smoke seal. A self-closing device will not be required. It is recommended that a fire rated fixed glazed panel is fitted to this door in order to allow borrowed light onto the staircase and ensure safe access and egress.
- See section 2.6 regarding the requirement for FD30s at the head of the basement and other requirements
- In all cases the door to the kitchen should be at least FD30S. Where a kitchen and living room are open plan, then a fire door to the kitchen is not appropriate;
- LD2 Grade D1 AFD; Interlinked mains wired smoke alarms with integral battery back up located in the escape route at all floor level, lounge and any cellar together with interlinked heat detection in the kitchen.
- An escape window at first floor level. Please see the Glossary for the requirements for escape windows. Where the conditions for escape windows cannot be met other solutions will need to be adopted and may include:
  - The construction of a 30-minute protected escape route inside the house
  - 60-minute separation between the ground and first floors
  - The installation of a water suppression system
  - The setting of conditions relating to facilities for calling the fire and rescue service in an emergency
- A fire blanket in the kitchen is required;
- Emergency lighting is only required in the escape route where the escape route is long and complex **or** where there is no effective borrowed light;
- Where an alternative scheme of fire safety measures is proposed, this may be accepted if it meets the relevant fire safety standards and with prior consent from the Housing Standards Team.

### 2.5.2 Two to Three Storey Back-to-Back (Single household)

- A door separating the ground to first floor should at least be FD30S. However in circumstances where the staircase from first to ground floor extends into the ground floor living room, then it may not be possible to fit a FD30S. In such cases it will be permissible to fit a fire door blank with intumescent strip and cold smoke seal. A self-closing device will not be required. In such cases it will be permissible to fit a fire door blank (a door which can be cut to any size) with intumescent strip and cold smoke seal. A self-closing device will not be required. It is recommended that a fire rated fixed glazed panel is fitted to this door in order to allow borrowed light onto

- the staircase and ensure safe access and egress.
- In all cases the door to the kitchen should be at least FD30S. Where a kitchen and living room are open plan, then a fire door to the kitchen is not appropriate;
  - See section 2.6 regarding the requirement for FD30s at the head of the basement and other requirements
  - LD2 Grade D1 AFD; Interlinked mains wired smoke alarms with integral battery back up located in the escape route at all floor level, lounge and any cellar together with interlinked heat detection in the kitchen.
  - An escape window at first floor level. Please see the Glossary for the requirements for escape windows. Where the conditions for escape windows cannot be met other solutions will need to be adopted and may include:
    - The construction of a 30-minute protected escape route inside the house
    - 60-minute separation between the ground and first floors
    - The installation of a water suppression system
    - The setting of conditions relating to facilities for calling the fire and rescue service in an emergency
  - A fire blanket in the kitchen is recommended;
  - Where an alternative scheme of fire safety measures is proposed, this may be accepted if it meets the relevant fire safety standards and with prior consent from the Housing Standards Team.

## **2.6 Basements and Cellars**

Consideration needs to be given to the fire risk presented to the occupiers of any storey below the main entry/exit level of the house. Such storeys may include true basements or lower ground floors where the main house entry level is raised above ground and accessed by steps.

Cellar ceilings within shared houses and bedsit HMO's should provide full 30 minutes resistance. Any openings around pipes, services or ducts that pass through fire-resisting construction should be fire stopped with materials of at least the same level of fire resistance as the structure itself.

Floor/ ceiling partitions between any basement or cellar and the ground floor escape route should provide 60 minutes resistance, but this may be reduced to 30 minutes where the basement/cellar has an automatic fire detection and warning system.

There should be AFD coverage in the basement/cellar areas. It should be of the same level as that installed in the remainder of the house. Large multi-roomed cellars may require a number of detectors as appropriate. As a minimum there should be interlinked hard wired smoke alarms with integral battery backup in the circulation area.

### **2.6.1 Habitable Basements**

- Thirty minute fire separation between the basement and ground floor, including the staircase soffit and spandrel, with a self-closing FD30S door fitted at the head of the basement stairs.  
*Note: for single household or low risk shared houses (both of no more than two storeys) the existing construction such as lath and plaster or plasterboard can be accepted provided it is sound and in traditional*



*materials. Also existing doors to all risk rooms can be accepted where they are solid, in a sound condition and self-closing. Lightweight doors and doors with very thin panels should be avoided.*

- In very large occupied basements, two FD30S doors (one at the top and one at the bottom of the basement staircase) are required. This is to ensure that occupiers do not have to escape through a trapped layer of smoke and heat;
- The route of escape from a basement habitable room should not pass through a risk room such as a living room or kitchen. Ideally a separate exit to an ultimate place of safety is required at basement level. However, where this is not possible escape windows should be provided to all habitable rooms in the basement (see the glossary for escape window requirements). If escape windows cannot be provided then a 30 minute protected route is required, and
- The AFD and warning system in the house should be extended to cover the basement. It should be of the same grade and type as that required for the remainder of the house.

## 2.6.2 Unoccupied Basements/Cellars

Unoccupied basements and cellars are often used for storage and usually contain gas and electric meters and electrical wiring. As a result fire can spread quickly and attack the underside of the ground floor, thus compromising the escape route at ground floor level.

- Thirty minute fire separation between the basement and the ground floor escape route, including the staircase soffit and spandrel, with a self-closing FD30S door fitted at the head of the basement stairs.

Note for single household or low risk shared houses (both of no more than two storeys), where the basement is well maintained, the existing construction such as lath and plaster or plasterboard can be accepted provided it is sound and conventional. Also an existing door at the head of the basement stairs can be accepted provided it is solid, in a sound condition and self-closing. Lightweight doors or those with very thin panels should be avoided.

There should be AFD coverage in the basement/cellar areas. It should be of the same level as that installed in the remainder of the house. Large multi-roomed cellars may require a number of detectors as appropriate. As a minimum there should be interlinked hard wired smoke alarms with integral battery backup in the circulation area.

## 2.7 Mixed use Premises

Residential accommodation is often situated above or within commercial premises. Any fire in the commercial premises will affect the residential parts, and at night may not be noticed until well developed.

A risk assessment will determine the level of risk but it is considered high risk where flats are located above shops, accommodation above a pub, hot food take-away or restaurant. Generally 60 minutes fire separation is required between the uses. It may be possible to reduce the separation to 30 minutes where there is an automatic fire detection system in the commercial parts which is linked to the

residential system subject to the fire risk assessment.

In some higher risk premises where 60-minute separation is achieved it may still be appropriate to provide an automatic fire detection system linked to the residential system subject to the fire risk assessment. In some cases where imperforate separation proves impracticable to achieve, compensatory measures should be considered such as fire protecting lobbies between the two uses, a secondary means of escape, or in high-risk situations a water suppression system in the commercial premises.

Because of the individual layout and mode of occupation of the residential part together with the type and layout of the commercial premises it is not possible to provide an ideal solution for the fire precautions required in these types of premises and you should consult with the HMO Team to discuss the requirements for individual properties.

## Glossary

### **Automatic Fire Detection (“AFD”)**

The presence of a suitable, properly installed and maintained fire detection and warning system will alert occupiers to the presence of a fire in its early stages and it will enable them to evacuate the house to a place of safety before escape routes become blocked by smoke or directly affected by fire. An AFD should therefore be designed to wake people who are sleeping and to alert the presence of a developing fire in any hidden areas such as a store room or cellar, before the fire affects the escape route.

### **Type and Grade**

AFDs are described by *type* and *grade*. **Type** refers to the parts of a property that the AFD covers, as described in the table below.

<b>AFD Type</b>	<b>Coverage</b>
LD1	a system installed throughout the premises, incorporating detectors in all circulation areas that form part of the escape routes from the premises, and in all rooms and areas, other than those with negligible sources of ignition, such as toilets, bathrooms and
LD2	a system incorporating detectors in all circulation areas that form part of the escape routes from the premises, and in all specified rooms or areas that present a high fire risk to occupants, including any kitchen and the principal habitable room
LD3	a system incorporating detectors in all circulation areas that form part of the escape routes from the premises.

- **Grade A:** AFDs (or monitored fire alarm systems) comprise a series of electrically operated smoke and/or heat detectors which are linked to a control panel that is normally located in the ground floor hallway of a property. The panel should comply with BS EN 54-2: + A1: and the wiring, siting and type of detectors and sounders with BS 5839: part1. BS 5839 is the British Standard that covers the design, installation and maintenance of fire alarm systems and AFDs should be fitted in accordance with it. Grade A AFDs are appropriate for higher risk HMOs as the control panel constantly monitors the detectors and sounders to ensure that they are functioning properly. If a fault occurs then the control panel indicates this;
- **Grade C:** A system of fire detectors and alarm sounders (which may be combined in the form of smoke alarms) connected to a common power supply, comprising the normal mains and a standby supply, with central control equipment.
  - **Grade D1 (System of one or more mains-powered smoke and/or heat alarms, each with a sealed-in standby supply consisting of a battery or batteries)** Grade D1 systems are recommended for fire detection and fire alarm systems in rented dwellings whether new, or existing, due to the potential

for a higher level of reliability that is appropriate because occupants of rented dwellings tend to be higher risk. Because it is able to operate in the event of a mains failure, a Grade D1 fire detection and fire alarm system may be connected to a lighting circuit. This has the advantage that the circuit is unlikely to be disconnected for a prolonged period of time. However, account needs to be taken of the potential difficulty of disabling a detector that is permanently in an alarm state, without isolating the lighting circuit

- **Grade D2 (system of one or more mains-powered smoke and/or heat alarms, each with an integral standby supply consisting of a user replaceable battery or batteries)** BS5839 recommends Grade D2 systems for use in new owner occupied dwellings. Owing to the possibility that the standby battery might be removed from the alarm, this part of BS5839 does not recommend that a Grade D2 system is installed in rented dwellings. Because it is able to operate in the event of a mains failure, a Grade D2 fire detection and fire alarm system may be connected to a lighting circuit. This has the advantage that the circuit is unlikely to be disconnected for a prolonged period of time. However, account needs to be taken of the potential difficulty of disabling a detector that is permanently in an alarm state, without isolating the lighting circuit.
- **Grade F1:** A system of one or more battery-powered detectors powered by a tamper-proof primary battery or batteries
- **Grade F2:** A system of one or more battery-powered detectors powered by a user-replaceable primary battery or batteries.

### **Detectors**

Smoke/heat detectors should be mains wired and inter-linked so that when one detector is activated all alarms sound. In addition each detector unit should have an integral sounder and battery standby supply. In order to avoid false alarms heat detectors should be fitted in rooms where cooking facilities are provided. Smoke detectors are required in all other areas, with the exception of bathrooms or WCs. However, if there is a risk of a fire starting in a bathroom or WC compartment, (i.e. if there is a source of ignition such as a wall mounted electric radiant fire) then a heat detector should be fitted. Note that electrically operated showers are not regarded as a source of ignition.

With regard to their sounding, the number of detectors fitted in a property and their siting should be such that, when *all doors are closed*, a sound level of 75 dB(A) minimum is achieved at the bed head. In all other accessible parts of the dwelling a sound level of not less than 65 dB(A) should be achieved.

### **Testing and Maintenance**

In accordance with The Smoke and Carbon Monoxide Alarm (England) Regulations 2015, landlords have a duty to ensure that smoke alarms are in proper working order at the start of each new tenancy.

All grades of system need to be tested periodically to ensure that there has not been any major failure. Fire detectors should also be cleaned periodically in accordance with the manufacturer's instructions.

The guidance of the manufacturer on the method by which the detector/alarm can be tested effectively should be followed. It is essential that fire alarm systems are subject to periodic inspection, so that unrevealed faults can be identified, and to enable preventive measures to be taken to ensure the continued reliability of the system.

Some routine testing does not require any specialist knowledge, and can normally be carried out, quite easily, by the occupier of the premises, who will, however, need simple instructions in how to do so.

- Instructions to users should stress the importance of routine testing of the system. It is essential that the occupiers understand the operation of the system, the action to take in the event of a fire alarm signal, the means for avoidance of false alarms, the procedures for testing the system and the need for routine maintenance of the system.
- For linked fire alarms (either wired or radio-linked) the link(s) should be tested to confirm that the signal can be successfully transmitted between devices.

Where a Grade A system is provided, periodic inspection and servicing needs to be carried out every 6 months by a competent person with specialist knowledge of fire detection and fire alarm systems. This is normally by a fire alarm servicing company. On completion of the work, any outstanding defects should be reported, and an inspection and servicing certificate should be issued which should be retained by the landlord/agent to show regular servicing.

In addition, Grade A systems should be tested every week in accordance with the recommendations of BS 5839 1:2017. The result of the weekly test and the identity of the manual call point used should be recorded in the system logbook.

All systems, (other than Grade A systems), should be tested at least every month. In the case of smoke alarms, heat alarms and multi-sensor fire alarms, this test may be carried out by use of a test button on every alarm installed in the premises. If an alarm has no test button, assistance with testing should be sought from a competent person. Periodic tests by a competent person of the fire alarm system (whether or not there is a test button), provides assurance that the fire alarm system is adequately maintained in accordance with licence conditions and provides some due diligence in the event of a fire.

The internal batteries of all detectors should be replaced within each detector in accordance with manufacturer's recommendations or when a low battery warning has been generated, whichever is the soonest.

#### *Grade A systems:*

- At least one detector or call point in each zone should be tested weekly to ensure correct operation. Any defects and remedial action should be recorded in the log book.
- A six-monthly service should be undertaken by a competent person, normally an alarm engineer, to carry out a full test as specified in BS 5839. This should be recorded in the logbook and a periodic inspection report and test certificate issued.

#### *Grade D systems:*

- The button of each alarm should be pressed every month and this action recorded in a logbook. This can be carried out by tenants where they have been provided with clear instructions for undertaking the test and recording the

- results. Faults or false alarms should be reported to the landlord or agent.
- The system should be cleaned periodically in accordance with the manufacturer's recommendations.

### **Commercial/ Domestic Property**

Where commercial accommodation is located in close proximity to residential uses, such as flats above shops, a risk assessment will determine the level of risk dependent on the type of residential and commercial premises. It is recommended that you consult with the HMO Team regarding the required fire precautions.

### **Emergency Lighting**

Emergency lighting should automatically illuminate when there is complete failure of the power supply to the artificial lighting or localised failure within the lighting circuit. It should illuminate an escape route to enable people to exit to a place of safety. It should also highlight any hazards such as stairs and changes in direction, and should enable easy identification of any manual fire alarm call points and fire fighting equipment along the route of escape.

In most cases the need for emergency lighting is determined by risk assessment. Factors to consider in the assessment include the size and layout of the property; the length of the escape route; the presence or absence of natural or borrowed light in the escape route and the vulnerability of the occupiers of the property.

If fitted, lights should be mounted approximately two metres above floor level (when measured to the underside of the luminaire) and in the following positions:

- Near any intersections of corridors;
- Above final exit doors;
- Near each change of direction (other than on a stairway);
- Within each stairway so that each flight of stairs receives direct light;
- Near each manual fire alarm call point;
- Outside any secondary escape exit if the street lighting is poor;
- Near each fire alarm call point; and
- Near fire fighting equipment.

Near is normally considered to be within two metres, measured horizontally. The route should be reasonably uniformly lit.

As with AFDs, emergency lighting systems should be routinely inspected and tested.

### **Escape Windows**

Escape windows will only be considered satisfactory if they meet building regulation requirements:

- They have an unobstructed openable area that is at least  $0.33\text{m}^2$ ; and none of the dimensions (height and width) is below 450mm, and the bottom of the openable area should not be more than 1100mm above the floor.  
If a width of a window is 450mm, the height must be at least 733mm in order to give the area of  $0.33\text{ m}^2$ . Alternatively, a window with the opening measuring 600mm x 550mm would achieve an area of  $0.33\text{m}^2$ .
- Please note that in situations where any part of an openable window is below 800mm from floor level, the window must have a quick release opening

restrictor suitable for means of escape windows. Any glazing extending to within 800mm of the floor level must be safety glass or glazed to meet Building Regulation requirements;

- They serve rooms whose floor level is no more than 4.5m from the ground;
- For shared and single household properties, entry to the room containing the escape window can be gained without the use of a key;
- The ground below the escape window is level and free from obstructions and other encumbrances, such as basement light wells and railings;
- They are openable from the inside without the use of a removable key, and
- They lead to a place of safety, clear of the building;
- Occupiers should be able-bodied individuals who can be reasonably expected to exit via the window unaided.

If these requirements cannot be met, the use of the escape window should not be accepted and an alternative solution should be adopted.

### **Fire Fighting Equipment**

Fire blankets and simple fire extinguishers can be useful in restricting the development and spread of small fires in their early stages. However, unless the fire is very small, occupants should be advised to evacuate the building to a place of safety and call the fire and rescue service.

### **Fire Extinguishers**

LACORS recommend that simple multi-purpose extinguishers are provided on each floor in the common parts of HMOs and buildings containing flats. However, the potential for extinguishers to be discharged through horseplay or malice in certain types of HMOs may negate this requirement. Suitable instructions and training should be given to tenants on their correct use at the start of the tenancy.

### **Fire Blankets**

With the exception of HMOs, fire blankets are recommended as good practice in kitchens of all houses, including single household occupation. Where provided they should be capable of dealing with small fires such as cooking fires or fires involving clothing, and they should comply with BS EN 1869:1997 or equivalent. They should be wall mounted (approximately 1.5m high) and situated sufficient distance from a cooking facility(ies) so that the blanket can be safely removed from its housing in the event of a fire. Note that they should be closer to the room exit than the cooking facility itself.

### **House In Multiple Occupation (“HMO”)**

A HMO is a property is defined in Section 254 of the Housing Act 2004. A HMO includes a property occupied by 3 or more unrelated people who make up 2 or more households (see the definition of “household” below) for the purposes of Part 1 of the Housing Act 2004 (Housing conditions and enforcement of housing standards). For Part 2 of the Act, which relates to the licensing of Houses in Multiple Occupation, a HMO is a property occupied by **3** or more unrelated people who make up 2 or more households. High risk HMOs, occupied by **5** or more unrelated people who share some or all basic amenities (kitchen, toilets and bathroom facilities) are required to be licensed under the provisions of Part 2 of the Housing Act 2004.

## **Household**

The term 'single household' is referred to Section 258 of the Housing Act 2004. A single household means either a single person or members of the same family who are living together. This includes people who are married or living together as a married couple (including same sex couples). 'Family' means specific relatives - parents, grandparents, children and step-children, grandchildren, brothers, sisters, uncles, aunts, nephews, nieces or cousins. Foster children are treated as part of their parent's household.

## **Inner Rooms**

An inner room is a room where the only escape route is through another high risk room, termed the "outer" or "access" room. Inner rooms present a risk to the occupier should a fire start unnoticed in an outer or access room.

An inner room situation may be accepted where the inner room is a bathroom, kitchen or WC room. However, where the inner room is a habitable room such as a bedroom, then the following must be considered in order to remove the high risk factor associated with this type of arrangement:

- Redesigning the layout by providing lobbies and corridors so that a traditional route of escape is created, or
- Where the inner room is small, removing where possible the structure between the inner and outer room, thereby creating one larger room.

Where the above have been considered and the inner room layout is still unavoidable, the following measures may be acceptable:

- The provision of an alternative exit from the inner room directly onto the route of escape; or
- The provision of an escape window from the inner room which will allow for rescue by the fire and rescue service (see the section on escape windows); and
- The provision of an FD30S door between the inner and outer room, AND
- The provision of an adequate AFD in the inner and outer room which should be of the same grade as that in the remainder of the building or flat.

In addition, the following requirements *must* be met for the arrangement to be acceptable:

- The outer room must be under the same control as the inner room;
- Nobody should have to pass through more than one outer room to make their escape, and;
- The outer room should not be a risk room. Where this is impracticable, an exit via a door or escape window may be an acceptable arrangement.

## **Manual Fire Alarms- Call Point**

A manual fire alarm system call point consists of break glass points that are situated next to final exit doors (and in larger multiple storey properties, on each landing). It allows the occupier of a property to raise the alarm in the event of a fire *prior* to the AFD being activated.

In most cases, with the exception of buildings converted into self-contained flats and Category A HMOs, the need for a manual fire alarm system is determined by risk assessment.



## **Protected Route of Escape and Fire Doors**

### **Protected Route**

A protected route should remain free from smoke and fire for a time to allow occupiers to pass safely along it to a place of safety. Ideally the standard of fire resistance enclosing the protected route is 30 minutes. To achieve this, the walls and ceilings to stairs, including the structure separating the ground floor and basement level, should be of 30 minute fire resisting construction. Sound lath and plaster can be regarded as this. However, if the plaster is un-keyed or perished, then it should be renewed or over-boarded. Surface coverings to walls and ceilings should be of a nature that will not assist the spread of flame.

Gas or electric meters located in cupboards that are large enough to be capable of storing potentially flammable materials and which are situated in the staircase enclosure, should be encased with materials with a 30 minute fire resistance.

Similarly storage cupboards situated within the staircase enclosure should be kept locked shut and lined with material to provide 30 minute fire resistance. A 30 minute fire door to the cupboard and an AFD fitted within the room.

Gas or electric meters and/or distribution boards should ideally not be sited in escape routes. However, it should be possible to relax this providing any gas meter is installed in accordance with the gas safety regulations and any electric meter is installed and sited in accordance with current IEE regulations. It is considered best practice to enclose such equipment in fire-resisting construction.

There is usually no requirement to provide protection to bathrooms and shower rooms which open onto protected routes. Properly installed and maintained central heating boilers, electric showers or water heaters and room-sealed gas water heaters pose little additional risk. However, if the room contains open flame or electric bar space heaters, storage cupboards or other risk items then either the storage cupboards or the room itself, as appropriate, should be protected to the appropriate standard in the same way as the remainder of the route.

In lower risk properties, for example an average single household occupancy, or 'low risk' shared houses, the standard for a protected route may be relaxed. In such cases, however the property must meet the following criteria:

- the stairs must lead directly to the final exit without passing through a risk room;
- the staircase enclosure must be of sound construction throughout the route;
- all risk rooms should be fitted with sound, close-fitting, conventional doors (lightweight doors and doors with very thin panels should be avoided); and
- an appropriate system of automatic fire detection and warning is in place.

A protected route should be maintained free from any obstructions and/or fire risks.

### **Fire Doors**

Where fire resisting walls are specified, then any doors within the wall must provide fire resistance to at least the same standard usually for 30 or 60 minutes. Fire doors are specified by the integrity performance time of the door set, being a frame and door manufactured to be fitted together. For example an *FD30* is a 30 minute fire door where the door or frame is fitted with an intumescent strip. A letter 'S' after the figure denotes a requirement for cold smoke seals to be fitted *in addition* to the intumescent strips e.g. *FD30S*.

It is recommended that existing doors and frames are replaced with a new doorset rather than being upgraded. However, where door frames are square and in sound condition they may be capable of being upgraded. Doors should not be upgraded unless they are of special architectural merit such as those used in listed buildings. Professional advice can be obtained from TRADA or English Heritage for technical advice on upgrading doors that have subject to fire tests.

All fire doors should be installed and maintained in accordance with BS 8214:2016

The final exit door(s) from an HMO or a building containing flats must be fitted with a lock that can be opened from the inside without the use of a key. Similarly doors separating units of accommodation from the escape route must be capable of being opened from the inside without the use of a key such as thumb turn locks.

Self-closing devices must be fitted to all entrance doors to flats and bedsit rooms complying with BS EN 1154:1997. They must also be fitted to fire doors on risk rooms in shared houses where it is deemed appropriate by risk assessment.

### **Risk Assessment**

For the purpose of this guidance “risk assessment” relates to a fire risk assessment, an organised and methodical look at premises. The aim of an assessment is to identify fire hazards in a house; to reduce the risk of those hazards causing harm to as low as reasonably practicable and to decide what physical fire precautions and management arrangements are necessary to ensure the safety of people in the premises if a fire does start. The assessment should be undertaken by the *responsible person* i.e. the person who has control of the premises. The principles of risk assessment for fire safety at Section 1 deals with risk assessment in greater detail.

### **Risk Room**

A risk room is a room with a function, where its use or contents present a risk of a fire occurring and developing. Typically this would be a kitchen, shared living room or bedsit room. However on risk assessment it could also include bedrooms due to their location, vulnerability of the tenant or any other factors which would increase the risk of fire. It excludes bathrooms and WC’s containing no fire risk.

### **Sprinkler & Mist Systems**

Water suppression systems detect, give warning, control, contain and often extinguish a fire. They consist of supply pipes that are permanently filled with water and fire suppression heads. The suppression heads are fitted with small thermal elements that are activated by heat. Each unit is independent and in most fires just one suppression head is operated.

Further advice should be sought from Building Control Services, West Yorkshire Fire and Rescue Service and the Housing Regulation/HMO Team should consideration be given to installing a water suppression system.

### **Storeys**

Storeys for fire safety purposes used in this guidance need to be counted from the final exit door to the uppermost level, including mezzanines as a storey. Where the final exit is located on the ground floor, or raised ground floor, any lower ground floor or basement or cellar should not be counted as a storey. In this guidance the travel distance to the final exit door is the factor in determining fire risk.

### **Whole Stair Lighting**

Such lighting comprises of a dedicated lighting circuit so that the use of any one switch/control anywhere along the route will illuminate the entire escape route. In the case of HMOs or flats with habitable basements, then two lighting systems can be installed. The first illuminates all floors at ground level and above, and the second illuminates the basement and ground floor levels. Where push button slow release light switches are used, the duration should be assessed, taking account of the travel distance in the circulation area to reach the flat or room from the final exit door and the mobility of the occupiers.